



icmr | **NIRT**
INDIAN COUNCIL OF MEDICAL RESEARCH | NATIONAL INSTITUTE FOR RESEARCH IN TUBERCULOSIS



आई सी एम आर – राष्ट्रीय यक्ष्मा अनुसंधान संस्थान
स्वास्थ्य अनुसंधान विभाग, स्वास्थ्य और परिवार
कल्याण मंत्रालय, भारत सरकार

ICMR - National Institute for Research in Tuberculosis
Department of Health Research, Ministry of Health
and Family Welfare, Government of India

Ref: No. e-tender/STORES/BSL-3 Lab/2019-20

Date: 08.01.2020

CORRIGENDUM

In pursuance to the recommendations of Pre-bid committee in its meeting held on 07/01/2020, the following modifications/changes have been made in the tender documents and brought to the notice of the interested tenderers concerned.

1. Biosafety Cabinet (page No. 50) :
Approximate Workspace of 1200mm(W)x660mm(D)x610mm(H)
2. Dunk Tank (page No. 50):
Approx size of dunk tank shall be 550mmx550mmx900mm
3. Performance requirements for HVAC System (page No. 33)
General:
 - Air Conditioner capacity should be 40T (+50% additional capacity as stand-by)
 - Isolation dampers for BiBo should be included
 - The corridor should be cordoned off with partition – GeneXpert Room entry to be created
 - Either of the doors in the drawings, preferably D1, could be converted as Emergency Exit
4. Uninterrupted Power Supply (UPS) – page No. 29
A central UPS console shall be provided to cater to the extreme essential power requirements of the laboratory in different capacities according to usage, one console meant for Exhaust AHU and the other meant for Biosafety Cabinet, Centrifuge, -20, MGIT machine, Refrigerator etc.
5. The last date of submission of tender is extended upto 15th January 2020.
Last date of Receipt of EMD: 14th January 2020.
Proposed date of Bid opening (online) 16th January 2020 (11 am)


ADMINISTRATIVE OFFICER